

| | | Size | Service date |
|---------------------------------|------------------|---------|--------------|
| Albemarle High School | Albemarle | 112kW | 9/15/16 |
| Baker-Butler Elem. School | Albemarle | 199kW | 9/15/16 |
| Brownsville Elem School | Albemarle | 107kW | 9/15/16 |
| Monticello High School | Albemarle | 219kW | 9/15/16 |
| Mortimer Sutherland MS | Albemarle | 224kW | 9/15/16 |
| Mary A. Greet | Albemarle | 56kW | 9/15/16 |
| St. Annes Belfield School | Albemarle | 315Kw | 9/15/17 |
| Peabody School | Albemarle | 100kW | 10/31/18 |
| Lyburn-Downing MS | Lexington | 84kW | 9/21/16 |
| Middlesex County Public Schools | Middlesex | 850kW | 8/16/18 |
| Middlesex HS | Middlesex | 720kW | 12/20/19 |
| Linwood Holton Elem. | Richmond | 120kW | 9/23/19 |
| Hugenot High School | Richmond | 540kW | 9/23/19 |
| M.J. Jones Elem | Richmond | 111kW | 9/23/19 |
| Martin Luther King Jr. MS | Richmond | 433kW | 9/25/19 |
| Oak Grove Elem. School | Richmond | 150kW | 9/23/19 |
| G.H. Reid Elem School | Richmond | 150kW | 9/23/19 |
| J.H. Blackwell Elem School | Richmond | 148kW | 9/23/19 |
| Broad Rock Elem. School | Richmond | 143kW | 10/31/19 |
| Lucille Murray Brown MS | Richmond | 360kW | 9/25/19 |
| J.B. Fisher Elem | Richmond | 100kW | 1/22/20 |
| Riverheads Elem | Staunton | 230kw | 7/1/19 |
| Riverheads HS | Staunton | 88kW | 7/1/19 |
| Wilson Elem | Augusta | 276kW | 7/8/19 |
| Wilson MS | Augusta | 231kW | 7/31/19 |
| Augusta S. Gordon Stewart MS | Augusta | 120kW | 12/31/20 |
| Augusta Wilson Memorial HS | Augusta | 200kW | 12/31/20 |
| Westmoreland County PS | Westmoreland | 660kW | 4/24/19 |
| Tuckahoe Elem. | Arlington | 17.9kW | 9/24/19 |
| Fleet Elem | Arlington | 500kW | 7/23/20 |
| Acquinton Elem | King William Cty | 625kW | 9/9/20 |
| Cool Spring Elem | King William Cty | 500kW | 9/9/20 |
| Kate Collins MS | Waynesboro | 295kW | 11/5/20 |
| Waynesboro HS | Waynesboro | 153.7kW | 11/17/20 |
| Carysbrook Elem | Fluvanna | 500kW | 8/13/20 |

| | | | | |
|---|----------------|----------|----------|----|
| Central Elem | Fluvanna | 144kW | 8/6/20 | |
| West Central Elem | Fluvanna | 300kW | 5/27/21 | |
| Fluvana MS | Fluvanna | 800kW | 6/30/21 | |
| Cool Spring Elem | Ashland | 233kW | 2/23/20 | |
| Hanover HS | Ashland | 466kW | 4/23/20 | |
| Laurel Meadow Elem | Ashland | 300kW | 4/2/20 | |
| Oak Knoll | Ashland | 532kW | 4/23/20 | |
| Flat Rock Elem | Powhatan | 200kW | 4/2/20 | |
| Pocohantas Elem | Powhatan | 333kW | 4/1/20 | |
| Powhatan Elem | Powhatan | 366kW | 4/4/20 | |
| Powhatan MS | Powhatan | 396kW | 4/7/20 | |
| Washington Dist. Elem School | Montross | 300kW | 12/30/19 | |
| Shenandoah County PS | Mt. Jackson | 220kW | 10/10/20 | |
| Ocean Lakes Elem | Virginia Beach | 366.60kW | 12/2/20 | |
| Renaissance Academy | Virginia Beach | 732.60kW | 1/13/21 | |
| Throughgood | Virginia Beach | 166.60kW | 12/3/20 | |
| Orange County Elem | Orange | 200kW | 12/31/20 | |
| Orange County HS | Orange | 215kW | 6/30/21 | |
| Orange County HS Field House | Orange | 120kW | 12/31/20 | |
| Orange Prospect Heights MS | Orange | 192kW | 5/11/21 | |
| Orange Taylor Education Administration Co | Orange | 200kW | 12/31/20 | |
| Gatewook Pre K-8 School | Newport News | 158kW | 9/16/20 | |
| Louisa MS | Mineral | 1000kW | 10/22/20 | |
| George Tyler MS | Isle of Wight | 599.4kW | 5/11/20 | |
| Windsor Elem | Isle of Wight | 467kW | 8/6/21 | |
| Edison HS | Fairfax | 1000kW | | ST |
| Justice HS | Fairfax | 1000kW | | ST |
| Mt. Vernon HS | Fairfax | 1000kW | | ST |
| Westfield HS | Fairfax | 1000kW | | ST |
| Falls Church HS | Fairfax | 509.5kW | | ST |
| South County HS | Fairfax | 1000kW | | ST |
| James Robinson HS | Fairfax | 1000kW | | ST |
| Robinson HS | Fairfax | 2000kW | | |
| Annandale HS | Fairfax | 1200kW | | |
| Hayfield HS | Fairfax | 2500kW | | |